

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12053

Period of Sept.1, 2024 – Sept. 30, 2024

Total Amount of Water Used per Period:	931,000gals.
Average Amount of Water Used per Day:	31,000 gals.
Total Amount of Hypochlorite Used per Period:	29.5 gals.
Average Amount of Hypochlorite Used per Day:	.98 gal

- Saturday Sept 9th
Cleaned filter bed 3
- Monday Sept 16th
sent monthly bac-t to the lab, also set up meeting with contractor for 395 culvert replacement project
- Tuesday Sept 17 received bac-t results
- Also set dates for waterline inspections for Oct 8th from 5 to 8 pm and Oct 12th from 8 am to noon
- Wednesday Sept 18th
- Received mark out request for dig safe for skyline drive for Schenectady co. hwy.

Wednesday Sept 21st 2024:

- Received culvert replacement plans for rt 395

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING. 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518)895-2100 YDD# 1-800-662-1220**