

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12953

Period of December 1, 2024- December 31, 2024

Total Amount of Water Used per Period: 869,000
Average Amount of Water Used per Day: 28,000
Total Amount of Hypochlorite Used per Period: 30 Gal
Average Amount of Hypochlorite Used per Day:.97 Gal

Tuesday December 2nd

- Mark out request 1714 Main street for house demolition/Dans demolition
- Friday December 5th Received monthly bac-t results

Saturday December 56th

- Cleaned filter bed 1

Tuesday December 9th

- Received an E-mail from Lamontt engineering confirming filter sand results that sand does not meet specs provided and a meeting needs to be scheduled to discuss this issue. Also we received the bill for sieve analysis from Construction Tech for sand samples I sent in from filter sand.

Thursday December 18th

- Received an e-mail and call from Brian Baker (Da.Collins contractor) wanting to set up a meeting with village to discuss culvert pipe replacement under Rt.395

Tuesday December 30th

- Cleaned filter bed 3.
-
-

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED..
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-
800-662-1220**