

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12953

Period of January 1, 2025- January 31, 2025

Total Amount of Water Used per Period: 1,128,000
Average Amount of Water Used per Day: 36,000
Total Amount of Hypochlorite Used per Period: 32.5 Gal
Average Amount of Hypochlorite Used per Day: 1.04 Gal

Tuesday January 16th

- Attended meeting at the water plant with Lamontt Engineering and Scott from Precision Industrial to go over sand removal procedures.
- January 5th cleaned filter bed

Tuesday January 21th

- Resident on East shore rd called in a water main break at 168 East shore rd.

Tuesday January 21th

- Repaired water main break, 4" water main, will need lawn cleaned up some and seeded in the spring.

Tuesday January 21th

- Received a call from Newton st. 168 no water, frozen pipes.
- Received a call from Erica Thompson (gray house next to tracks , Rob novenski owner, no water, frozen pipes.
-
-

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED..
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-
800-662-1220**