

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12953

Period of November 1, 2024- November 30, 2024

Total Amount of Water Used per Period: 805,000
Average Amount of Water Used per Day: 27,000
Total Amount of Hypochlorite Used per Period: 24.5 Gal
Average Amount of Hypochlorite Used per Day:.81 Gal

Sunday November 3rd

- Received the test results back from construction tech. I forwarded the results to Lamontt Engineering.
- We received the wrong sand in filter beds. The sand does not meet the specs that were submitted to sand supplier.

Thursday November 7th

- Canceled hydrant flushing due to lack of water in the reservoir.

Friday November 8th

- Dig safe mark out request on Rail Road Ave, installed electric pedestal for harvest homes.

Thursday November 14th

- Received monthly Bac-T results.

Saturday November 23rd

- Cleaned filter bed #2.

Tuesday November 26th

- Cleaned filter bed #3.

Wednesday November 27th

- Received test results for the THM and HA5 and I forwarded them to Lamontt Engineering.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED..
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-
800-662-1220**