

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12953

Period of March 1, 2025- March 31, 2025

Total Amount of Water Used per Period: 1,046,000
Average Amount of Water Used per Day: 34,000
Total Amount of Hypochlorite Used per Period: 30.5 Gal
Average Amount of Hypochlorite Used per Day:.98 Gal

Tuesday March 4th

- Worked on East shore rd locating water main break
- Sent 1st quarter Thm & Ha5 to Jason for the EPA update

Wednesday March 5th

- Water main break on East shore Rd located and fixed 343

Monday March 10th

- Attend informational meeting at village hall from Lamontt engineering

Monday March 17th

- Issued a stop work order at Sunbelt as they were washing construction mats

Wednesday March 18th

- Mark out request from dig safe for Schenectady county highway dept on Skyline drive

Monday March 31st

- Mark out request from dig safe, utility company on Main Street, around pole 19.5.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED..
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUI;DING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-
800-662-1220**