

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main St. P.O. Box 235  
Delanson, New York 12953

---

**Period of May 1, 2025- May 31, 2025**

Total Amount of Water Used per Period: 891,000  
Average Amount of Water Used per Day: 31,000  
Total Amount of Hypochlorite Used per Period: 17.5 Gal  
Average Amount of Hypochlorite Used per Day .56 Gal

Thursday May 1st

- Received a message from trustee Grenier they are injecting poly urethane into the rot holes in the culvert under rt.395 in effort to stop water flow in the old culvert to install new pipe .his concern , never mentioned at any pre-construction meetings.
- Tuesday May 6<sup>th</sup> dig safe mark out /alexander rd

Wednesday May 7<sup>th</sup>.

- Received a call from resident on east shore rd low water pressure. Checked pressure in the village and confirmed we have a water break down over the embankment on rt 395 across from school.Called the health dept. reported the break had to shut the water off from school drive to the lower half of the village at 11pm till 8am to conserve water while break was being fixed.Notified village residents of a boil water advisory and posted it on village website.

.Thursday May 8th

- Boil water order from health dept. notified through village website and emergency line from health dept.Repaired water break.

Friday May 9th

Sampled 2 times for boil water order and sent to lab. Boil water order was lifted after receiving notification samples were clear from lab.

Friday May 16<sup>th</sup> call from resident on east shore rd. low water pressure.Responded to water plant opened valves from clearwell number 3&2 all the way after trying to get them back on line after water break.

Wednesday May 21<sup>st</sup>. Respond to water plant , received a call from Steve Whiley from NYS Dot.of a chemical spill cement additive in the cement that flowed out of the cement truck and went down the embankment into the reservoir and down rt.395. Notified the health Dept. immediately, shut down water plant ,called affordable water to have water delivered.From this point on several state agencies were notified and they determined there was no threat to drinking water.I had asked State Doh. to please put that in e-mail to save to files.

Saturday May 24<sup>th</sup>

- Received permission from the state health dept. to put the water plant back on line.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED..  
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF  
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> & INDEPENDENCE AVE. SW,  
WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-  
800-662-1220**