

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main St. P.O. Box 235  
Delanson, New York 12953

---

**Period of Nov. 1, 2025- Nov 30, 2025**

Total Amount of Water Used per Period: 852,000

Average Amount of Water Used per Day: 27,000

Total Amount of Hypochlorite Used per Period: 20 Gal

Average Amount of Hypochlorite Used per Day .65 Gal

Monday Dec 10th

- Contacted the local health dept. pertaining to the sanitary survey conducted this past year to have the report corrected by the state health dept.
- Lamontt engineering also contacted the health dept.pertaining to the incorrect information and clarify there report and asked for a new corrected report.

Friday Dec 19th

- Received 4<sup>th</sup> quarter Thm & Ha5 sample results and foward them to Jason Lamontt engineering to report to the EPA.

Tuesday Dec 23th

- Received confirmation that Asst.water commissioner completed his water license and they would be issuing him a water license now.
- Throughout the month of Dec.put filter bed #1 back on line but a week later had to remove it again as turbidity levels rose too high.I have contacted Jason @ Lamontt engineering and advised him of the situation.

**DCOMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR,  
OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUI;DING, 14<sup>TH</sup> &  
INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2100  
202500410 (518) 895-2100 TDD# 1-800-662-1220**