

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main St. P.O. Box 235  
Delanson, New York 12953

---

**Period of Nov. 1, 2025- Nov 30, 2025**

Total Amount of Water Used per Period: 594,000

Average Amount of Water Used per Day: 20,000

Total Amount of Hypochlorite Used per Period: 19 Gal

Average Amount of Hypochlorite Used per Day .63 Gal

Monday Nov 10th

- Start sand removal filter bed 1, Percision vac truck
- Mark out request dig safe 1920 main street Gifford res.

Tuesday Nov 11th

- Finish sand removal filter #1

Wednesday Nov 26th

- Monthly bac-t results,also sampled for thm,ha5

Saturday Nov 29th

Started re-sanding filter bed#1

- Sunday Nov 30<sup>th</sup>  
Finished re-sanding  
filterbed#1

**DCOMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR,  
OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUI;DING, 14<sup>TH</sup> &  
INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2100  
202500410 (518) 895-2100 TDD# 1-800-662-1220**