

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12953

Period of Oct. 1, 2025- Oct 31, 2025

Total Amount of Water Used per Period: 677,000

Average Amount of Water Used per Day: 22,000

Total Amount of Hypochlorite Used per Period: 25.5 Gal

Average Amount of Hypochlorite Used per Day .82 Gal

Tuesday Oct 7th 8th

- Brown, discolored water complaint 1772 main street
- Complaint 138 thousand acre rd brown water

Friday Oct.9th

- Flushed hydrants on main street to help remediate brown ,discolored water complaints.

Friday Oct 23rd

- Emergency locate 1812 mudge rd

Friday Oct 23rd

- picked up wash table for re-sanding filter bed from Ft.Plain water dept.
Also contacted Percision (scott) for time frame to remove sand from filter bed

Emergency mark out request , East shore rd pole replacement

DCOMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-800-662-1220