

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12953

Period of Feb 1, 2025- Feb 28, 2025

Total Amount of Water Used per Period: 968,000
Average Amount of Water Used per Day: 35,000
Total Amount of Hypochlorite Used per Period: 19.5 Gal
Average Amount of Hypochlorite Used per Day .70 Gal

Wednesday Feb 4th

- Responded to West shore rd Maleyzk res.(old Ferris res.)for frozen water service line. Froze past curb box under rd.way. Had to thaw line.

Thursday Feb 5th

- Responded to 1966 main street another frozen water service line frozen under 395 had to thaw line.

Wednesday Feb 11th

- Responded to 1748 main street frozen water service. Water service is frozen on homeowners side of curb stop homeowners responsibility.

Tuesday Feb 17th

- Responded to Harvest homes no water.Determined water service was frozen on there side of valve box.

Saturday Feb 21st Turned water off at red house on 395 dr.cooley rental next to Basset health care building .Pipes frozen and broke house is vacant.Notified son-in-law.

DCOMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUI;DING, 14TH & INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-800-662-1220